



Друштво са ограниченом одговорношћу за производњу и дистрибуцију  
енергије и флуида и пружање услуга  
**ЕНЕРГЕТИКА КРАГУЈЕВАЦ**  
34000 Крагујевац, Косовска 4А

Телефон: 034/304-783; Факс: 034/304-783; e-mail: [jnabavka@energetika-kragujevac.com](mailto:jnabavka@energetika-kragujevac.com)  
PIB: 101576503; МБ: 17006100; Број жиро-рачуна: 205-211835-30 Комерцијална банка

Date: April 19th, 2018

## FOR POTENTIAL BIDDERS

**Subject:** Reply to a request for additional information or clarification regarding the preparation of the bid

At the request of an interested party for the additional information or clarification regarding the preparation of bids in an open public procurement procedure whose object are goods, "**Reconstruction of Boiler Room "ZASTAVA" with the purpose of replacing a part of the capacity of coal-fired boilers with the combined natural gas-powered and heavy fuel oil-powered boilers, Phase I**" - number of the public procurement **1.1.47 / 2017**, Purchaser in accordance with Article 63 of the PPL, publishes answer.

### Questions:

On pages 16 and 31 of the tender documentation, in the part where the standards for which the burner has to be fitted are stated, a (in all likelihood) printing error occurred. Namely, the mentioned standard for burners is a standard: EN 3849-1 (this standard does not exist) and should be: EN 13849-1 (discharged 1 at the beginning of the number). Please check that there is no typing error, since this standard does not exist, but there is EN 13849-1.

### Answers:

This is a technical error, it is standard EN 13849-1. There will be a correction in the tender documentation on pages 16 and 31.

**Since the tender documentation is changed for more than 8 days from the date foreseen for final submission and opening of tenders, it will not be extended and will remain as it was until now – 07th of may 2018. until 10:00 am and 10:30 am.**

**Commission for public procurement No. 1.1.47/2017**